American Nuclear Society

WITHDRAWN

April, 1990 ANSI/ANS-2.10-1979 guidelines for retrieval, review, processing and evaluation of records obtained from seismic instrumentation

an American National Standard

No longer being maintained as an American National Standard. This standard may contain outdated material or may have been superseded by another standard. Please contact the ANS Standards Administrator for details.



published by the American Nuclear Society 555 North Kensington Avenue La Grange Park, Illinois 60525 USA American National Standard
Guidelines for Retrieval, Review,
Processing and Evaluation of Records Obtained
from Seismic Instrumentation

Secretariat American Nuclear Society

Prepared by the American Nuclear Society Standards Committee Working Group ANS-2.10

Published by the American Nuclear Society 555 North Kensington Avenue La Grange Park, Illinois 60525 USA

Approved January 8, 1979 by the American National Standards Institute, Inc.

National Standard

American An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review and users are cautioned to obtain the latest editions.

> CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this Standard no later than five years from the date of publication. Purchasers of this Standard may receive current information, including interpretation, on all standards published by the American Nuclear Society by calling or writing to the Society.

Published by

American Nuclear Society 555 North Kensington Avenue, La Grange Park, Illinois 60525 USA

Price: \$20.00

Copyright © 1979 by American Nuclear Society.

Any part of this Standard may be quoted. Credit lines should read "Extracted from American National Standard, ANSI/ANS-2.10-1979, with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Foreword

(This Foreword is not a part of American National Standard Guidelines for Retrieval, Review, Processing and Evaluation of Records Obtained from Seismic Instrumentation, ANSI/ANS-2.10-1979.)

The purpose of this standard is to specify for light water-cooled, land-based nuclear power plant guidelines for timely retrieval and evaluation of records obtained from seismic instrumentation specified in American National Standard Earthquake Instrumentation Criteria for Nuclear Power Plants, ANSI/ANS-2.2-1978.

This standard sets forth guidelines on how the records obtained from such instrumentation should be treated.

The December, 1973 version of Title 10, Code of Federal Regulations, Part 100, "Seismic and Geologic Criteria for Nuclear Power Plants," requires that a nuclear power plant be shut down in the event that the Operating Basis Earthquake (OBE) is exceeded. This standard provides guidelines for a timely evaluation of data used to determine whether or not the OBE has been exceeded. Guidance to the utility or its agents is provided in connection with the following activities:

- (1) Retrieval of recorded data from seismic instrumentation in the event an earthquake occurs sufficient to activate the seismic instrumentation.
- (2) Correction or modification of the recorded data to minimize spurious or erroneous signals.
- (3) Preliminary evaluation of the corrected recorded data to estimate the degree of earthquake excitation in terms of the levels of earthquake excitation used as the plant design bases.
- (4) Analysis applied to the corrected recorded data to obtain calculated results which can be used to compare with plant components seismic design bases.
- (5) Final comparison of recorded seismic data, including the calculated results, and evaluations of the comparisons.
 - (6) Storage and maintenance of recorded data and subsequent calculations.

This standard does not deal with operator procedures to accomplish plant shutdown due to seismic activity, restarting of plants after shutdown due to seismic activity, or any power plant operator functions.

When an earthquake occurs, seismic data are recorded by the seismic instrumentation and are either immediately available through remote recording or annunciation or can be obtained by extracting recorded data manually from the activated seismic instrumentation. The remotely obtained data are used to make an early determination of the degree of severity of the seismic event in terms of the seismic design bases. This data will be used to make the initial determination of whether the plant should be shut down, if it has not already been shut down by normal mechanisms due to component malfunction, or has been required to be shut down due to operation perturbations observed by the control room operator. If, on the basis of this initial evaluation, it is concluded that the seismic design has not been exceeded, it is presumed that the plant will not be shut down. However, additional studies may be undertaken to evaluate possible long-term effects and to document the recorded response and the calculated results. These studies may be minimal depending on the initial evaluation.

In the event that the initial evaluations result in the conclusion that the plant should be shut down, this standard sets forth guidelines for analysis techniques and comparison methods which can be used to arrive at a conclusion as to whether the plant can be safely re-started on the basis of seismic considerations. The sequence of owner activities is set forth in Figure 1 which is intended to serve as the "road map" for the standard. Specific existing regulations or codes are not necessarily included in the scope of this standard and are set forth in other documents.

This standard was prepared by Working Group ANS-2.10 of ANS-2 subcommittee, Site Evaluation, of the American Nuclear Society Standards Committee.

The first draft was submitted to the Subcommittee for their review and for industry

comment on May 15, 1975. The working group reviewed the comments received from the Subcommittee and industry and the draft dated September 1, 1976 was sent to the Subcommittee for balloting. The Subcommittee approved the draft with some comments. These comments were reviewed and incorporated in a draft dated January 24, 1977. Comments received from N18 have been reviewed and implemented leading to the current draft dated February 28, 1978.

Working Group ANS-2.10 of the Standards Committee of the American Nuclear Society had the following membership:

- A. K. Vaish, Chairman, EDS Nuclear Inc.
- L. Benuska, Kinemetrics, Inc.
- P. M. Blanch, Northeast Utilities Service Company
- M. M. B. Chan, Brown and Root, Inc.
- P. D. Engdahl, Engdahl Enterprises
- L. E. Escalante, Los Angeles Department of Water and Power
- D. Godfrey, Duke Power Company
- K. G. Hazifotis, General Electric Company
- P. Ibanez, Applied Nucleonics Company, Inc.
- P. S. Klasky, Teledyne Geotech
- C. W. Lin, Westinghouse Electric Corporation
- W. J. Lindblad, Pacific Gas and Electric Company
- D. S. Mehta, Bechtel Power Corporation
- D. K. Ostrom, Southern California Edison Company
- H. Polk, U.S. Nuclear Regulatory Commission
- R. Srinivasan, Sargent and Lundy Engineers
- L. E. White, Stone and Webster Engineering Corporation

The membership of Subcommittee ANS-2, Site Evaluation, at the time of its approval of this standard was:

- R. V. Bettinger, Chairman, Pacific Gas and Electric Company
- L. E. Escalante, Los Angeles Department of Water and Power
- J. A. Fischer, Dames and Moore
- M. I. Goldman, NUS Corporation
- W. W. Hays, U.S. Geological Survey
- G. E. Heim, Sargent and Lundy Engineers
- G. F. Hoveke, Sargent and Lundy Engineers
- G. S. Hunt, Southern California Edison Company
- D. H. Johns, Southern California Edison Company
- U. Kappus, Dames and Moore
- R. E. Keever, Nuclear Technology, Inc.
- E. J. Keith, EDS Nuclear Inc.
- A. K. Vaish, EDS Nuclear Inc.

- C. R. McClure, Bechtel Corporation
- S. J. Milioti, American Electric Power Service Corporation
- G. Nicholas, Dames and Moore
- T. Pickel. Oak Ridge National Laboratory
- I. C. Roberts, U.S. Nuclear Regulatory Commission
- P. J. Ryan, Bechtel Corporation
- J. M. Smith, General Electric Company
- I. J. Spickler, Dames and Moore
- J. D. Stevenson, Nuclear Structural Systems Association
- W. S. Tucker, Florida Power and Light Company
- N. R. Wallace, Bechtel Corporation
- D. A. Wesley, General Atomic Company
- K. Wiedner, Bechtel Power Corporation

American National Standards Committee N18, Nuclear Design Criteria, had the following membership at the time it approved this standard:

L. J. Koch, ChairmanC. B. Zitek, Secretary

Organization Represented	Name of Representative
American Chemical Society	
American Concrete Institute	P. E. Mast L. J. Koch
American Society of Mechanical Engineers	
American Public Health Association, Inc. American Welding Society Atomic Industrial Forum Electric Light & Power Group	J. R. Coleman J. R. McGuffey G. G. Sherwood J. E. Howard
Federal Power Commission	J. E. Sohngen (Alt)A. P. Donnell B. P. Chew (Alt)
Health Physics Society	
Institute of Electrical & Electronics Engineers	
Institute of Nuclear Materials Management	L. A. Strom (Alt)
Nuclear Energy Liability & Property Insurance Association	F. Catudal L. P. Mariani (Alt)
U.S. Energy Research & Development Administration	F. X. Gavigan
U.S. Nuclear Regulatory Commission	
Individual Members	E. N. Cramer R. J. Creagan J. F. Gibbons T. D. Jones T. J. Pashos D. Patterson A. H. Redding G. C. Robinson R. P. Schmitz G. L. Wessman J. F. West C. B. Zitek

Contents	Sec	Pag Pag	e
	1.	Scope	1
	2.	Purpose	1
	3.	Definitions	1
	4.	Earthquake Decision Tree for a Nuclear Power Plant	
	5.	Data Retrieval and Evaluation 5.1 Instrument Characteristics and Status 5.2 Immediate Data Logging (Relates to Level 1) 5.3 Transmission of Data from Site 5.4 Data Reduction 5.5 Data Evaluation	3 4 4
	6.	Analysis and Comparative Studies 6.1 General 6.2 Seismic Design Data 6.3 Mathematical Model 6.4 Analysis Procedures 6.5 Results Comparison	6 6 6 7
	7.	Additional Evaluations	8
	8.	References	8
	Fig	ure 1 — Earthquake Decision Tree	.0
	Tal	ble 1 — Activities Description (Reference to Figure 1)	l 1
	Ap	pendix	15