

American Nuclear Society

WITHDRAWN


March 3, 1993

ANSI/ANS-2.7-1982

**Criteria and guidelines for assessing capability
surface faulting at nuclear power plant sites**

an American National Standard

**No longer being maintained as an
American National Standard. This
standard may contain outdated material
or may have been superseded by
another standard. Please contact the
ANS Standards Administrator for
details.**



published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60525 USA

**American National Standard
Criteria and Guidelines for Assessing Capability
for Surface Faulting at Nuclear Power Plant Sites**

**Secretariat
American Nuclear Society**

**Prepared by the
American Nuclear Society
Standards Committee
Working Group ANS-2.7**

**Published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60525 USA**

**Approved August 19, 1982
by the
American National Standards Institute, Inc.**

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review and users are cautioned to obtain the latest editions.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of this standard may receive current information, including interpretation, on all standards published by the American Nuclear Society by calling or writing to the Society.

Published by

American Nuclear Society
555 North Kensington Avenue, La Grange Park, Illinois 60525 USA

Price: \$16.00

Copyright © 1982 by American Nuclear Society.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard, ANSI/ANS-2.7-1982, with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Foreword

(This Foreword is not a part of American National Standard Criteria and Guidelines for Assessing Capability for Surface Faulting at Nuclear Power Plant Sites, ANSI/ANS-2.7-1982.)

This standard is intended to provide applicants and consultants with criteria and guidelines for investigations for assessing the potential for surface faulting at nuclear power plant sites.

The Code of Federal Regulations, Title 10, "Energy," Part 100, "Reactor Site Criteria," Appendix A, "Seismic and Geologic Siting Criteria For Nuclear Power Plants," includes required investigations for surface faulting. These regulations in part include criteria for obtaining information to determine whether, and to what extent, a nuclear power reactor facility need be designed for surface faulting. Whereas Appendix A of 10 CFR 100 lists the criteria for surface faulting determination, methods and procedures for obtaining the data needed for the assessment of the potential for surface faulting are the responsibility of the applicant. In the past, applicants and consultants have been faced, at times, with conducting difficult and expensive investigations of capable faulting, including age dating, without full knowledge of the available methods and procedures.

Considerable experience in assessing the "capability" for surface faulting at nuclear power plant sites has been accumulated by the industry at many sites across the nation. Whereas reports of these faulting investigations are available in open files of the Nuclear Regulatory Commission, the approaches and the results of these evaluations are not widely disseminated. Consequently, the need arose to develop some type of guideline or standard outlining available methods and procedures for making an acceptable assessment of the potential for surface faulting. American National Standard Criteria and Guidelines for Assessing Capability for Surface Faulting at Nuclear Power Plant Sites, ANSI/ANS-2.7-1982, was developed to fulfill this need.

Although the objective of this standard is clearly defined, the procedures for attaining the objective cannot be defined specifically. Following a series of set procedures does not assure that a reasonable or acceptable assessment of the capability for surface faulting at a specific site has been made. The assessment in many situations derives from the judgment of qualified professionals based on interpretations of complex groups of data at various levels of accuracy and completeness. These guidelines are based on a consensus of a group of professionals knowledgeable in the geologic and seismic aspects of faulting.

ANS-2.7-1982 is not intended to restrict or limit alternate approaches or innovations in assessing the capability for surface faulting. Understandably, there may be situations in which methods or procedures other than those addressed in ANS-2.7-1982 would provide the data needed for assessing the potential of surface faulting at power plant sites.

The members of working group ANS-2.7 who prepared this document are:

C. R. McClure, Chairman, *Bechtel Civil and Minerals, Inc.*
C. R. Allen, *California Institute of Technology*
R. L. Blum, *Pacific Gas & Electric Company*
M. G. Bonilla, *U. S. Geological Survey*
L. S. Cluff, *Woodward-Clyde Consultants*
G. B. Dalrymple, *U. S. Geological Survey*
*M. B. Dobrin, *University of Houston*
G. O. Gates, *Consultant*
D. H. Hamilton, *Earth Sciences Associates*
R. H. Jahns, *Stanford University*

R. A. Laurence, *U. S. Geological Survey*
V. J. Murphy, *Weston Geophysical Engineers, Inc.*
S. W. Smith, *University of Washington*
R. E. Wallace, *U. S. Geological Survey*
P. J. West, *Southern California Edison Company*
G. S. Hunt, *Southern California Edison Company*
R. D. McMullen, *U. S. Nuclear Regulatory Commission*

* Deceased

Subcommittee ANS-2, Site Evaluation, of the American Nuclear Society Standards Committee had the following members at the time of its approval of this standard:

R. V. Bettinger, Chairman, <i>Pacific Gas and Electric Company</i>	S. J. Milioti, <i>American Electric Power Service Corporation</i>
L. L. Beratan, <i>U. S. Nuclear Regulatory Commission</i>	G. W. Nicholas, <i>Dames & Moore</i>
A. Brearley, <i>Sargent & Lundy</i>	R. M. Noble, <i>R. M. Noble & Associates</i>
L. E. Escalante, <i>Los Angeles Department of Water and Power</i>	T. Pickel, <i>Oak Ridge National Laboratory</i>
M. I. Goldman, <i>NUS Corporation</i>	D. L. Siefken, <i>U.S. Nuclear Regulatory Commission</i>
W. W. Hays, <i>U. S. Geological Survey</i>	J. M. Smith, <i>General Electric Company</i>
G. E. Heim, <i>Harding-Lawson Associates</i>	I. Spickler, <i>Dames & Moore</i>
D. H. Johns, <i>Southern California Edison Company</i>	J. D. Stevenson, <i>Woodward-Clyde Consultants</i>
U. Kappus, <i>Dames & Moore</i>	S. Tucker, <i>Florida Power & Light Company</i>
E. J. Keith, <i>EDS Nuclear Inc.</i>	A. K. Vaish, <i>EDS Nuclear Inc.</i>
C. R. McClure, <i>Bechtel Civil & Minerals, Inc.</i>	R. W. Whalin, <i>U.S. Army Corps of Engineers</i>
	K. Wiedner, <i>Bechtel Power Corporation</i>

The American Nuclear Society's Nuclear Power Plant Standards Committee (NUPPSCO) had the following membership at the time of its approval of this standard:

J. F. Mallay, Chairman
M. D. Weber, Secretary

<i>Name of Representative</i>	<i>Organization Represented</i>
G. A. Arlotto	U.S. Nuclear Regulatory Commission
R. G. Benham	General Atomic Company (for the Institute of Electrical and Electronics Engineers, Inc.)
R. W. Allen, Alt.	United Engineers and Constructors (for the Institute of Electrical and Electronics Engineers, Inc.)
R. V. Bettinger	Pacific Gas & Electric Company
P. Bradbury	Westinghouse Advanced Reactor Division
D. A. Campbell	Westinghouse Electric Corporation
C. O. Coffey	Kaiser Engineers Power Corporation
L. J. Cooper	Nebraska Public Power District
W. H. D'Ardenne	General Electric Company
C. J. Gill	Bechtel Power Corporation
H. J. Green	Tennessee Valley Authority
W. Johnson	Catalytic, Inc.
A. R. Kasper	Combustion Engineering, Inc.
R. W. Keaten	GPU Service Corporation
J. W. Lentsch	Portland General Electric Company
J. F. Mallay	Babcock & Wilcox Company (for the American Nuclear Society)
A. T. Molin	United Engineers & Constructors
J. H. Noble	C. T. Main, Inc.
E. P. O'Donnell	Ebasco Services (for the Atomic Industrial Forum)
T. J. Pashos	Nuclear Services Corporation
M. E. Remley	Atomics International
J. W. Stacey	Yankee Atomic Electric Company
S. L. Stamm	Stone & Webster Engineering Corporation
J. D. Stevenson	Woodward-Clyde Consultants (for the American Society of Civil Engineers)
G. P. Wagner	Commonwealth Edison Company
G. L. Wessman	Torrey Pines Technology
J. E. Windhorst	Southern Company Services, Inc. (for the American Society of Mechanical Engineers)
E. R. Wiot	NUS Corporation

Contents	Section	Page
1. Scope and Purpose	1	1
1.1 Scope	1	1
1.2 Purpose	1	1
2. Definitions	1	1
3. Criteria for Determining Capability	2	2
3.1 Capable Fault Evidence	2	2
3.2 Non-capable Fault Evidence	2	2
3.3 Ambiguous Evidence	2	2
4. Probability of Surface Faulting	3	3
5. Recognition of Faults	3	3
5.1 Geologic	4	4
5.2 Topographic and Geomorphologic	4	4
5.3 Hydrologic	4	4
5.4 Geophysical (Other Than Earthquake Seismology)	4	4
5.5 Seismologic	4	4
5.6 Horizontal and Vertical Deformation	4	4
5.7 Other Categories	5	5
5.8 Features that may be Confused with Surface Faulting	5	5
6. Age Determination of Faults	5	5
7. Methods and Techniques of Investigation	5	5
7.1 Literature and Data Research	5	5
7.2 Geologic Investigations on Land	6	6
7.3 Geologic Investigation in Water-Covered Areas	6	6
7.4 Laboratory Investigations	6	6
7.5 Geophysical Investigations on Land	6	6
7.6 Geophysical Investigations in Water-Covered Areas	6	6
7.7 Seismological Investigations	6	6
7.8 Detection of Deformation and Analysis of State of Stress	6	6
8. Reporting of Results	6	6
9. References	7	7