American Nuclear Society

REAFFIRMED

May 13, 1987 ANSI/ANS-8.9-1987 nuclear criticality safety criteria for steel-pipe intersections containing aqueous solutions of fissile material

WITHDRAWN

May 13, 1997 ANSI/ANS-8.9-1987

an American National Standard

No longer being maintained as an American National Standard. This standard may contain outdated material or may have been superseded by another standard. Please contact the ANS Standards Administrator for details.



published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60525 USA

ANSI/ANS-8.9-1987 Revision of ANSI/ANS-8.9-1978

American National Standard Nuclear Criticality Safety Criteria for Steel-Pipe Intersections Containing Aqueous Solutions of Fissile Materials

Secretariat
American Nuclear Society

Prepared by the American Nuclear Society Standards Committee Working Group ANS-8.9

Published by the American Nuclear Society 555 North Kensington Avenue La Grange Park, Illinois 60525 USA

Approved April 3, 1987 by the American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under the procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to assure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Head-quarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

American Nuclear Society 555 North Kensington Avenue, La Grange Park, Illinois 60525 USA

Copyright © 1987 by American Nuclear Society.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-8.9-1987 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Foreword

(This Foreword is not a part of American National Standard Nuclear Criticality Safety Criteria for Steel-Pipe Intersections Containing Aqueous Solutions of Fissile Materials, ANSI/ANS-8.9-1987.)

Basic parameters and practices for nuclear criticality control outside reactors are described in American National Standard for Nuclear Criticality Safety in Operations with Fissionable Materials Outside Reactors, ANSI/ANS-8.1-1983, and in documents referenced therein. However, for the most part, the data in that standard are single parameter limits.

In the past there has been a paucity of experimental and calculated data for geometric arrangements, such as crosses, ells, and tees, for storage and processing of aqueous solutions of fissile materials in pipes. This situation resulted in overly conservative applications which became evident soon after Work Group 8.9 undertook the drafting of a standard on this subject in 1968. Over the succeeding years, additional experimental data and advanced computational technology became available and now provide the means to reduce the conservatism in industrial practice and permit greater flexibility in process applications. The American National Standard Nuclear Criticality Safety for Pipe Intersections Containing Aqueous Solutions of Enriched Uranyl Nitrate, ANSI/ANS-8.9-1978, has been extended to include typical aqueous solutions of fissile materials and, in particular, uranium containing no more than 5 wt% ²³⁵U. Acceptable configurations are presented as standard schedule pipe sizes for a variety of parameters.

In order to facilitate the applicability of this standard allowances have been made for situations which cannot be known or controlled absolutely. The specifications given in this standard are based upon validated calculations in which consideration of an adequate margin of subcriticality included variations in chemical concentrations ($k_{\rm eff} \sim 0.03$), a bias in calculations of solution systems ($k_{\rm eff} \sim 0.02$), the influence of container materials ($k_{\rm eff} \sim 0.05$), and a minimum margin of subcriticality ($k_{\rm eff} \sim 0.05$). Thus, the systems as specified have a nominal $k_{\rm eff}$ of 0.85. Submerged intersections have a nominal $k_{\rm eff}$ of 0.90. Generally, fissile and other materials will be present in addition to aqueous fissile solutions contained in piping. It will be necessary for a safety specialist to evaluate their reactivity contribution to proposed pipe intersections in order to confirm compliance with requirements of the standard. It would be unusual for a design not to require review by a safety specialist.

This standard was prepared by Work Group ANS-8.9, under the guidance of American Nuclear Society Standards Subcommittee 8. The Work Group, chaired by J. T. Thomas, was comprised of the members of the Subcommittee 8 and J. E. Bigelow, Oak Ridge National Laboratory.

The membership of Subcommittee 8, Fissionable Materials Outside Reactors, at the time of preparation and approval of this revision was:

- J. T. Thomas, Chairman, Martin Marietta Energy Systems, Inc.
- E. B. Johnson, Secretary, Oak Ridge National Laboratory
- F. M. Alcorn, Babcock and Wilcox Company
- H. K. Clark, Savannah River Laboratory
- E. D. Clayton, Battelle Pacific Northwest Laboratories
- D. M. Dawson, Battelle Memorial Institute
- M. C. Evans, British Nuclear Fuels plc
- N. Ketzlach, U. S. Nuclear Regulatory Commission
- R. Kiyose, University of Tokyo
- W. G. Morrison, Exxon Nuclear Idaho Co., Inc. (Retired)
- D. R. Smith, Los Alamos National Laboratory
- G. E. Whitesides, Martin Marietta Energy Systems, Inc.
- F. E. Woltz, Goodyear Atomic Corporation

 $Consensus\ Committee\ N16,\ Nuclear\ Criticality\ Safety,\ which\ reviewed\ and\ approved\ this\ standard\ in\ 1985,\ had\ the\ following\ membership:$

Dixon Callihan, Chairman E. B. Johnson, Secretary

	American Institute of Chemical Enginers
Dixon Callihan	
Ricardo Artigas	. American Society for Testing and Materials (Liaison only)
D. Frank Cronin	Atomic Industrial Forum
Leo E. Hansen	Exxon Nuclear Company, Inc.
Representative not Assigned	
C. Leslie Brown	
William T. Mee, alt.	
William R. Waltz	Savannah River Laboratory
Blake P. Brown	U.S. Department of Energy
George H. Bidinger	U.S. Nuclear Regulatory Commission
Elizabeth B. Johnson, Individual	AND THE PROPERTY OF A SECURE OF THE STATE OF THE STATE OF THE SECURE OF
Hugh C. Paxton, Individual	
Fred W. Sanders, Individual	·

Contents	Section	Page	
	1. Introduction		
	2. Scope	1	
	3. Definitions 3.1 Limitations 3.2 Shall, Should, and May 3.3 Glossary of Terms		
	4. Nuclear Criticality Safety Practices	2	
	5. Specifications for Pipe Intersections 5.1 Reflector Conditions 5.2 Aqueous Uranium Solutions 5.3 Aqueous Plutonium Solutions 5.4 Aqueous ²³³ U Solutions	2	
	6. Application of Criteria	3	
	7. References	3	
	Tables		
	Table 1 Table 2 Table 3 Table 4	6 7	
	Figures	4	
	Fig. 1 Area of Intersection	4 4	
	Reflector Condition	4	