

American Nuclear Society

WITHDRAWN

August 29, 2011
ANSI/ANS-58.6-1996; R2001

criteria for remote shutdown
for light water reactors

an American National Standard


No longer being maintained as an American National Standard. This standard may contain outdated material or may have been superseded by another standard. Please contact the ANS Standards Administrator for details.

REAFFIRMED

August 31, 2001
ANSI/ANS-58.6-1996 (R2001)

This standard has been reviewed and reaffirmed with the recognition that it may reference other standards and documents that may have been superseded or withdrawn. The requirements of this document will be met by using the version of the standards and documents referenced herein. It is the responsibility of the user to review each of the references and to determine whether the use of the original references or more recent versions is appropriate for the facility. Variations from the standards and documents referenced in this standard should be evaluated and documented.

This standard does not necessarily reflect recent industry initiatives for risk informed decision-making or a graded approach to quality assurance. Users should consider the use of these industry initiatives in the application of this standard.



published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60525 USA

**American National Standard
Criteria for Remote Shutdown
for Light Water Reactors**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Subcommittee MC-1**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Approved February 7, 1996
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Copyright © 1996 by American Nuclear Society. All rights reserved.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-58.6-1996 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Foreword

(This Foreword is not a part of American National Standard Criteria for Remote Shutdown for Light Water Reactors, ANSI/ANS-58.6-1996.)

Criterion 19 of the General Design Criteria for Nuclear Power Plants, contained in Appendix A of Title 10, "Energy," Code of Federal Regulations, Part 50, "Licensing of Production and Utilization Facilities," stipulates that a control room be provided for safe unit operation, and also that controls external to this control room be provided with a capability to achieve hot shutdown for boiling water reactors, hot standby for pressurized water reactors, and a potential capability to achieve cold shutdown. This standard addresses the criteria necessary for controls external to the control room in response to the latter part of Criterion 19, "Control Room." In addition, the alternate (or alternative) or dedicated shutdown criteria of 10 CFR 50 Appendix R, "Fire Protection Program for Nuclear Power Facilities Operating Prior to January 1, 1979"—now embodied in the acceptance criteria of the NRC Standard Review Plan 9.5.1 and the NRC Branch Technical Position CMEB 9.5-1—are addressed in this revision.

A specific mechanism for control room evacuation is not postulated in this standard or in Criterion 19, although the working group did specifically consider a fire-induced control room evacuation during revision of the standard. Mechanistic events occurring within the control room are beyond the scope of this standard, but should be addressed in other standards, particularly one dealing with control room design and philosophy. Other standards provide interfacing criteria and design requirements, including electrical and control system criteria. Thus, this standard should be regarded as only one of a group of standards which collectively address plant safety and control.

The criteria are divided into two parts: Assumptions for Design, and Criteria for Remote Shutdown. Although the second part gives the criteria specifically needed to define remote shutdown operation, the designer cannot implement these criteria without proper consideration of surrounding effects and conditions throughout the plant. Consequently, the first part gives guidance in the form of assumptions about plant operating conditions. A combination of the two parts is then used by the designer to allow an integrated approach to implement the remote shutdown requirements.

In general, the criteria require a design which allows the operator to place the plant in a "tripped" condition, leave the control room, and continue shutdown operation at a remote station. An Alternate Shutdown Station is the centralized location for central administration and communication in the event of a control room evacuation occurrence. Local Control Station(s) (e.g., at breaker panels) throughout the plant may be utilized in coordination with the Alternate Shutdown Station. The Alternate Shutdown Station and the Local Control Station(s) are separate and remote from the control room and cable-spreading areas. From these shutdown locations, the safety-related functions of reactivity control, core coolant inventory control, pressure control, and core residual heat removal can be administered and monitored as needed to maintain a safe shutdown. The systems and controls needed are required to be capable of operation from normal and emergency power supplies and must have other attributes normally associated with safety-related systems. However, since the control room evacuation occurrence is a "special event", the single failure criterion does not apply; i.e., an additional single failure is not postulated to occur in addition to the occurrence which requires evacuation of the control room. In order to limit the possibility of unintended simultaneous operation of the plant from the control room and the

alternate or local control shutdown locations, the criteria require Control Transfer Devices to be installed, or administrative procedures to be used, to permit operations to be from only one location at any time. In order to initiate remote shutdown operation, the Control Transfer Devices must be in the appropriate mode.

This standard was originally developed under ANS-51 and balloted affirmatively by that committee. Subsequently, the N18 Committee, Nuclear Design Criteria, balloted on the standard in April 1978. Further review and comments were received from the American Nuclear Society's Nuclear Power Plant Standards Committee (NUPPSCO) in October 1979. Subsequently, the standard was balloted by NUPPSCO in March 1980 and further reviewed at a July 1980 NUPPSCO meeting. The 1983 version of the standard is based on resolution of ballot comments and further review at the November 1981 NUPPSCO meeting.

The standard was reaffirmed at the March 1989 NUPPSCO meeting subject to a general revision of the standard. Such a revision was balloted by the ANS Management Committee MC-1 in its October 1992 meeting and the standard was balloted by NUPPSCO in its April 1993 meeting.

This revision of the standard was prepared under the direction of Subcommittee MC-1, LWR Management Committee, of the Standards Committee of the American Nuclear Society, and the revision effort was chaired by **M. P. Horrell, Raytheon Nuclear Inc.** The membership of MC-1 at the time of preparation was:

J.T. Luke, Chairman, *Florida Power & Light Company*
J.C. Dempsey, Jr., *Pacific Nuclear*
L.E. Ettlinger, *Defense Nuclear Facilities Safety Board*
J.C. Glynn, *U.S. Nuclear Regulatory Commission*
P.H. Hepner, *ABB/Combustion Engineering Nuclear Power*
R.A. Hill, *GE Nuclear Energy*
M.P. Horrell, *Raytheon Nuclear Inc.*

L.A. Klosowski, *Niagra Mohawk Power Corporation*
G.G. Locklear, *Brunswick Steam Electric Plant*
S.A. Nass, *Duquesne Light Company*
N. Prillaman, *The Babcock & Wilcox Company*
H.C. Shaffer, *Yankee Atomic Electric Company*
S.A. Shuman, *Stone & Webster Engineering Corporation*
M.D. Smith, *Bechtel Corporation*
R.C. Surman, *Westinghouse Electric Corporation*

The American Nuclear Society's Nuclear Power Plant Standards Committee (NUPPSCO) had the following membership at the time of its approval of this standard:

W. H. D'Ardenne, Chairman

M. D. Weber, Secretary

R. E. Allen	UE&C Nuclear (for the Institute of Electrical and Electronics Engineers, Inc.)
P. Ballinger	Nebraska Public Power District
S. Bhattacharya	Pacific Gas & Electric Company
F. Boorboor	Nuclear Placement Services, Inc.
J. C. Bradford	Bechtel National, Inc.
T. W. T. Burnett	Westinghouse Electric Corporation
J. D. Cohen	Westinghouse Savannah River Company
J. B. Cotton	Philadelphia Electric Company
T. A. Daniels	Rochester Gas & Electric Corporation
W. H. D'Ardenne	GE Nuclear Energy (for the American Nuclear Society)
L. E. Davis	Commonwealth Edison Company
S. B. Gerges	NUS Corporation, Inc.
D. L. Gillispie	Institute of Nuclear Power Operations
G. L. Gyorey	GE Nuclear Energy
P. H. Hepner	ABB/Combustion Engineering Inc.
C. E. Johnson	U.S. Nuclear Regulatory Commission
J. T. Luke	Florida Power & Light Company
J. F. Mallay	Liberty Consulting Group
R. E. Miller	Duke Power Company
J. A. Nevshemal	United Engineers & Constructors, S-R Division
W. B. Reuland	Electric Power Research Institute
T. T. Robin	Southern Company Services
J. C. Saldarini	Raytheon Nuclear Inc.
R. E. Scott	Scott Enterprises
D. J. Spellman	Oak Ridge National Laboratory
S. L. Stamm	Stone & Webster Engineering Corporation
J. D. Stevenson	Stevenson & Associates
C. D. Thomas, Jr.	Yankee Atomic Electric Company
G. P. Wagner	Commonwealth Edison Company
N. Weber	Sargent & Lundy
R. Weir	Tennessee Valley Authority

Contents	Section	Page
	1. Introduction	1
	1.1 Scope	1
	1.2 Purpose	1
	2. Definitions	1
	3. Assumptions for Design	3
	4. Criteria and Provisions for Remote Safe Shutdown	3
	5. References	7
	Tables	
	Table 1 Instrumentation for Alternate Shutdown	5