

American Nuclear Society


WITHDRAWN

May 19, 2012
ANSI/ANS-2.2-2002

earthquake instrumentation
criteria for nuclear power plants

an American National Standard

No longer being maintained as an American National Standard. This standard may contain outdated material or may have been superseded by another standard. Please contact the ANS Standards Administrator for details.



published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA

**American National Standard
Earthquake Instrumentation
Criteria for Nuclear Power Plants**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Working Group ANS-2.2**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Approved November 21, 2002
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Copyright © 2003 by American Nuclear Society. All rights reserved.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-2.2-2002 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Foreword

(This Foreword is not a part of American National Standard “Earthquake Instrumentation Criteria for Nuclear Power Plants,” ANSI/ANS-2.2-2002.)

The purpose of this standard is to specify for water-cooled nuclear power plants the minimum requirements for earthquake instrumentation. Should an earthquake occur, the instrumentation provides information on the vibratory ground motion and resultant vibratory responses of representative Category I structures [defined in U.S. Nuclear Regulatory Commission (NRC) Regulatory Guide 1.29, “Seismic Design Classification”] so that an evaluation can be made as to

- (1) whether or not the design response spectra have been exceeded;
- (2) whether or not the motion was damaging through determination of its Cumulative Absolute Velocity (CAV) as defined in American National Standard “Criteria for the Handling and Initial Evaluation of Records from Nuclear Power Plant Seismic Instrumentation,” ANSI/ANS-2.10-2003;
- (3) whether or not the calculated vibratory responses used in the design of the representative Category I structures and equipment have been exceeded at instrumented locations;
- (4) the degree of applicability of the mathematical models used in the seismic analysis of the building and equipment.

In addition, instrumentation could be provided to furnish specific information that would increase knowledge and understanding of seismic design. The problem of determining what additional instrumentation is needed to perform this function should be the basis of research and development programs and is not addressed in this standard.

The seismic design of nuclear power facilities requires, in part,

- (1) the determination of an input vibratory grounded motion for the site. Input vibratory ground motion could be described by “response spectra,” or time-history earthquake records. Most nuclear plant owners have specified their design input vibratory ground motion by response spectra in the form of “design response spectra” in their license application to the NRC;
- (2) the construction of mathematical models for dynamic analysis from which the vibratory response of structures and equipment to the input vibratory ground motion can be calculated.

Seismic designs for nuclear power plants utilize advanced analytical and design techniques. Therefore, evidence that the earthquake response spectra did not exceed appropriate spectrum values or that the CAV showed that the motion was not damaging, in accordance with ANSI/ANS-2.10-2003, would give reasonable assurance that plant structures and equipment were not damaged or made inoperable. In addition, the determination by actual instrument data of the resultant vibratory responses of representative structures and equipment and the check of the applicability of mathematical models used in the dynamic analysis would give further assurance that plant structures or equipment was not damaged.

When an earthquake occurs, it is important to determine as soon as possible (within 4 hours) whether or not the free-field motion exceeded predetermined conditions in accordance with ANSI/ANS-2.10-2003. An ideal instrumentation system would immediately provide usable data in a convenient form for making this determination. Through the use of commercially available instruments, the necessary functions of this ideal instrumentation system can be provided. The

providing of these functions is the basis for the minimum requirements specified in this standard.

The basic and most important instrument for measuring vibratory motion is the time-history accelerograph, which measures and records absolute acceleration as a function of time during an earthquake. This may be a self-contained instrument, or it may consist of acceleration sensors, which detect absolute acceleration and transmit the data to a remote central recorder. From the resulting time-history records, the peak accelerations and duration can be determined, and the response spectra and CAV can be derived by computation.

This standard was prepared by Working Group ANS-2.2 of the American Nuclear Society Standards Committee. This is a major revision to the ANSI/ANS-2.2-1988 standard. All comments received were reviewed and, where possible, were incorporated. Working Group ANS-2.2 had the following membership during its work on this standard:

D. K. Ostrom, Chair, *Individual*

C. Angstadt, *Cleveland Electric Illuminating Company*
M. L. Crumb, *TERRA Technology Corporation*
J. Diel, *Agbabian & Associates*
P. D. Engdahl, *Engdahl Enterprises*
R. P. Kassawara, *Electric Power Research Institute*
R. M. Kenneally, *U.S. Nuclear Regulatory Commission*
J. McCumber, *Yankee Atomic Electric Company*
T. O'Hara, *Yankee Atomic Electric Company*
R. Srinivasan, *Structural Integrity Associates*
J. Stevenson, *Stevenson & Associates*
A. Y. C. Wong, *Stone & Webster Engineering Corporation*

NFSC (formerly known as NUPPSCO) was the consensus committee at the time ANS-2.2 was approved. The consensus committee had the following membership:

J. C. Saldarini, Chair, *Raytheon Nuclear*

G. P. Wagner, Vice-Chair, *ComEd*

Suriya Ahmad, Secretary, *American Nuclear Society*

R. H. Bryan, *Tennessee Valley Authority*
T. W. Burnett, *Westinghouse Electric Corporation*
H. Chander, *U.S. Department of Energy*
J. D. Cohen, *Westinghouse Savannah River Company*
L. E. Davis, *ComEd*
W. H. D'Ardenne, *Individual*
L. A. Ettlinger, *The Oxford Group*
P. H. Hepner, *ABB/Combustion Engineering Nuclear Power*
R. A. Hill, *GE Nuclear Energy*
N. P. Kadambi, *U.S. Nuclear Regulatory Commission*
J. T. Luke, *Florida Power & Light Company*
J. F. Mallay, *Liberty Consulting Group*
C. H. Moseley, *Performance Development Corporation*
J. A. Nevshemal, *Raytheon Engineers & Constructors*
S. A. Nass, *Duquesne Light Company*
N. Prillaman, *Framatome Technologies*
W. C. Ramsey, Jr., *Southern Company Services, Inc.*
W. B. Reuland, *Mollerus Engineering Corporation*
J. Savy, *Lawrence Livermore National Laboratory*
R. E. Scott, *Scott Enterprises*
S. L. Stamm, *Stone & Webster Engineering Corporation*
J. D. Stevenson, *J. D. Stevenson Consultants*
C. D. Thomas, *Yankee Atomic Electric Company*
G. P. Wagner, *ComEd*
G. J. Wrobel, *Rochester Gas & Electric*

Contents	Section	Page
	1 Scope	1
	2 Purpose	1
	3 Definitions	1
	4 General Information and Requirements	2
	4.1 Instrument Description	2
	4.2 Data Analysis	2
	4.3 Data Information	3
	4.4 Required Sensor Locations	3
	4.5 Instrumentation at Multiunit Sites	4
	4.6 Interconnection of Instruments	4
	4.7 Timeliness of Data Evaluation	4
	5 Instrument Requirements	4
	5.1 General	4
	5.2 Acceleration Sensor(s)	4
	5.3 Recorder	5
	5.4 Seismic Trigger	5
	5.5 Time-History Accelerograph	5
	6 Instrumentation Station Installation	5
	6.1 Accessibility	5
	6.2 Design and Installation	5
	6.3 Orientation	6
	6.4 Actuation	6
	6.5 Remote Indication	6
	6.6 Accuracy	6
	6.7 Instrumentation Station Environment	6
	6.8 Protection	6
	7 Accompanying Materials	6
	8 Other Instruments	6
	9 Surveillance	6
	9.1 General	6
	9.2 Schedule	7
	9.3 Test Data Requirements	7
	10 References	8
	Appendixes	
	Appendix A Instrumentation Location Guide	9
	Figures	
	Figure 1 Earthquake Instrument Locations	3