



Criteria for Retrieval, Processing, Handling, and Storage of Records from Nuclear Facility Seismic Instrumentation

An American National Standard

Published by the
American Nuclear Society
555 N. Kensington Ave
La Grange Park, IL 60526



**American National Standard
Criteria for Retrieval, Processing, Handling,
and Storage of Records from
Nuclear Facility Seismic Instrumentation**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Working Group ANS-2.10**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Approved December 19, 2017
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under the procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Inquiries about requirements, recommendations, and/or permissive statements (i.e., “shall,” “should,” and “may,” respectively) should be sent to the Scientific Publications and Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**



This document is copyright protected.

Copyright © 2017 by American Nuclear Society. All rights reserved.

Any part of this standard may be quoted. Credit lines should read “Extracted from American National Standard ANSI/ANS-2.10-2017 with permission of the publisher, the American Nuclear Society.” Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Inquiry Requests

The American Nuclear Society (ANS) Standards Committee will provide responses to inquiries about requirements, recommendations, and/or permissive statements (i.e., “shall,” “should,” and “may,” respectively) in American National Standards that are developed and approved by ANS. Responses to inquiries will be provided according to the Policy Manual for the ANS Standards Committee. Nonrelevant inquiries or those concerning unrelated subjects will be returned with appropriate explanation. ANS does not develop case interpretations of requirements in a standard that are applicable to a specific design, operation, facility, or other unique situation only and therefore is not intended for generic application.

Responses to inquiries on standards are published in ANS’s magazine, *Nuclear News*, and are available publicly on the ANS website or by contacting the ANS Scientific Publications and Standards Department.

Inquiry Format

Inquiry requests shall include the following:

- (1) the name, company name if applicable, mailing address, and telephone number of the inquirer;
- (2) reference to the applicable standard edition, section, paragraph, figure, and/or table;
- (3) the purpose(s) of the inquiry;
- (4) the inquiry stated in a clear, concise manner;
- (5) a proposed reply, if the inquirer is in a position to offer one.

Inquiries should be addressed to:

American Nuclear Society
Scientific Publications and Standards Department
555 N. Kensington Avenue
La Grange Park, IL 60526

or standards@ans.org

Foreword

(This foreword is not a part of American National Standard “Criteria for Retrieval, Processing, Handling, and Storage of Records from Nuclear Facility Seismic Instrumentation,” ANSI/ANS-2.10-2017, but is included for informational purposes.)

The purpose of this standard is to specify criteria for the treatment of records obtained from nuclear facility analog and digital strong-motion seismic instrumentation. A nuclear facility is defined as any facility that, as a result of its operation, generates waste material containing or potentially containing radioactive materials. This includes, but is not limited to, nuclear power plants, hospitals, fuel fabrication facilities, fuel reprocessing facilities, radioactive waste disposal facilities, industrial facilities, and research facilities. The principal function of the seismic instrumentation covered in this standard is to address issues that have a significant bearing on safety or mitigate the consequences of accidents that could result in potential off-site exposures. For light-water-cooled nuclear power plants, seismic instrumentation is specified in ANSI/ANS-2.2-2016, “Earthquake Instrumentation Criteria for Nuclear Power Plants.” For non-power nuclear facilities, seismic instrumentation, if required, is specified in facility-specific regulations, standards, and/or guidance documents.

This standard sets forth criteria on how the records obtained from strong-motion instrumentation should be retrieved, processed, handled, and stored after an earthquake. This standard does not address weak-motion instrumentation installed in some non-power nuclear facilities to measure small-magnitude ground accelerations or velocities.

Three major changes to the 2003 standard have been incorporated as below:

- this standard addresses both power and non-power nuclear facilities;
- this standard also covers the retrieval and the subsequent processing, handling, and storage of analog instrumentation data consistent with that located in older operating nuclear facilities; and
- this standard does not cover the evaluation of the records taken from seismic ground and structure motion locations used (1) to determine if the operating basis earthquake ground motion has been exceeded and (2) in long-term evaluations, if necessary; these are discussed in ANSI/ANS-2.23-2016, “Nuclear Power Plant Response to an Earthquake.”

The state of the practice for nuclear power plant seismic instrumentation type, location, requirements, and surveillance is provided in ANSI/ANS-2.2-2016. The state of the practice for nuclear power plant pre-earthquake planning, post-earthquake short-term actions, determination of the earthquake damage and recommended action, post-shutdown inspections and tests, and long-term evaluations is provided in ANSI/ANS-2.23-2016. These standards can be used as guidance in assessing existing or developing new requirements and guidance for non-power nuclear facilities.

Criteria for the plant’s owner or its agents are provided in connection with the following activities:

- (1) retrieval of recorded data from seismic instrumentation in the event that an earthquake occurs with sufficient ground-shaking motion to activate the seismic instrumentation;
- (2) correction of the recorded data to minimize non-earthquake effects;
- (3) storage, handling, and maintenance of recorded data and calculations.

Currently, this standard applies to land-based nuclear power plants and non-power nuclear facilities that deploy strong-ground-motion instrumentation. This standard has been reviewed by the ANS-2.10 Working Group for its applicability to nuclear power plant seismic monitoring instrumentation based on different technologies utilized in operating nuclear power plants. The ANS-2.10 Working Group will review, from time to time, this standard's applicability to new nuclear power plants and non-power nuclear facility installations based on different technologies from current facilities and will verify that the purposes and criteria of this standard are preserved.

This standard might reference documents and other standards that have been superseded or withdrawn at the time the standard is applied. A statement has been included in the references section that provides guidance on the use of references.

This standard does not incorporate the concepts of generating risk-informed insights, performance-based requirements, or a graded approach to quality assurance. The user is advised that one or more of these techniques could enhance the application of this standard.

The first version of ANS-2.10 was approved in 2003. It was administratively withdrawn as an American National Standard in April 2013 as it did not comply with the American National Standards Institute's requirement to complete maintenance within ten years. This standard, ANSI/ANS-2.10-2017, addresses the treatment of data from both digital and analog instrumentations and incorporates changes that have occurred in the industry practice since the 2003 standard was developed.

This standard was prepared by the ANS-2.10 Working Group of the American Nuclear Society Standards Committee. All comments received were reviewed and, where possible, were incorporated. The ANS-2.10 Working Group had the following membership during its work on this standard:

J. Xu (Chair), *U.S. Nuclear Regulatory Commission*

R. B. Darragh, *Pacific Engineering and Analysis*

T. Elkhoraibi, *Bechtel Corporation*

V. Graizer, *U.S. Nuclear Regulatory Commission*

B. J. Gutierrez, *U.S. Department of Energy, Savannah River*

A. Hashemi, *Bechtel Corporation*

R. P. Kassawara, *Electric Power Research Institute*

R. M. Kenneally, *Individual*

R. Nigbor, *Individual*

D. Ostrom, *Individual*

A. Shakal, *California Geological Survey, Strong Motion Instrumentation Program*

C. Stephens, *U.S. Geological Survey*

The Siting: Seismic Subcommittee had the following membership at the time of its approval of this standard:

Q. A. Hossain (Chair), *Lawrence Livermore National Laboratory*

J. Xu (Vice Chair), *U.S. Nuclear Regulatory Commission*

D. K. Clark, *Consolidated Nuclear Security, LLC*

E. Gibson, *Schnabel Engineering*

K. L. Hanson, *Individual*

R. P. Kassawara, *Electric Power Research Institute*

S. McDuffie, *U.S. Department of Energy*
F. Ostadan, *Bechtel Corporation*
I. Wong, *Lettis Consultants International*

The Environmental and Siting Consensus Committee (ESCC) had the following membership at the time of its approval of this standard:

C. A. Mazzola (Chair), *Project Enhancement Corporation*
Y. Gao (Vice Chair), *Westinghouse Electric Company*

T. Bellinger, *Consolidated Nuclear Security, LLC*
D. A. Bruggeman, *Los Alamos National Laboratory*
K. R. Bryson, *Individual*
J. Call, *Oaysis, Inc.*
J. P. Doub, *U.S. Nuclear Regulatory Commission*
Q. A. Hossain, *Lawrence Livermore National Laboratory*
R. J. Hunt, *Consolidated Nuclear Security, LLC*
Y. Li, *Defense Nuclear Facility Safety Board*
K. Y. Ng, *Bechtel Corporation*
J. O'Brien, *U.S. Department of Energy*
L. S. Parks, *U.S. Nuclear Regulatory Commission*
J. B. Savy, *Individual*
A. Simpkins, *Dade Moeller, an NV5 Company*
P. B. Snead, *Duke Energy*
S. A. Vigeant, *APTIM Corp.*
J. Xu, *U.S. Nuclear Regulatory Commission*

ESCC Observer:

R. B. Harvey, *U.S. Nuclear Regulatory Commission*

Contents

Section	Page
1 Scope	1
2 Purpose	1
3 Acronyms and definitions	2
3.1 Acronyms	2
3.2 Shall, should, and may	2
3.3 Definitions	2
4 Data retrieval, processing, handling, and storage	4
4.1 Instrument characteristics and status	4
4.1.1 Documentation of facility instrumentation characteristics	5
4.1.2 Operational status	5
4.2 Data retrieval	6
4.2.1 General	6
4.2.2 Data identification	7
4.2.3 Record preparation	7
4.2.4 Immediate data logging	8
4.3 Transmission of data from the site	8
4.4 Data reduction	8
4.4.1 Engineering units	8
4.4.2 Data preparation	8
4.4.3 Data processing	9
4.5 Response spectrum plots	9
5 References	10
 Appendix	
Appendix Commentaries and Guidance	11