

ERRATUM

American National Standard Earthquake Instrumentation Criteria for Nuclear Power Plants ANSI/ANS-2.2-2002

Section 9.4, Seismic Monitoring Instrumentation Surveillance Requirements, was unintentionally left out of the standard during the publication process. This erratum completes the standard.

9.4 Seismic Monitoring Instrumentation Surveillance Requirements

Inst.	Channel Check	Channel Functional Test	Channel Calibration
T/A	-Power supply voltage -Recording and display units -Alarms	-All channel checks -Frequency and damping of all sensor units -Visual inspection of accessible sensor units -Replacement of desiccant in remote housings	-All channel checks and functional tests -Amplitude -Dynamic range -Sensor natural frequency and damping
S/T	-Power supply voltage -Alarms	-Functional test of all sensor units -Power supply voltage -Alarms -Visual inspection of accessible units -Replacement of desiccant in remote housings	-All functional tests -Threshold set points